

Annexure D

BUILDING SAFETY CERTIFICATE

No. **AEO: NO: 1 PWD SD Bang 2024-25 / 763**

Dated: 21-02-2025

It is certified that the existing Building CLARUS INTERNATIONAL SCHOOL at Survey No. 24/1 & 24/2, GORAVIGERE, KANNAMANGALA POST, BIDARAHALLI HOBALI, Bangalore EAST, Bangalore-560067 is having block (s) Floor(s) as per details below:

One (01) Block

Block-1 Comprised of Ground Floor, First Floor & Second Floor.

Owned/occupied by **CLARUS INTERNATIONAL SCHOOL** at Survey No. **24/1 & 24/2, GORAVIGERE, KANNAMANGALA POST, BIDARAHALLI HOBALI, Bangalore EAST, Bangalore-560067** have complied with the Building Safety requirements in accordance with National Building code Rules and verified by the officers concerned of **KARNATAKA PUBLIC WORKS DEPARTMENT** on **20/02/2025** in the presence of **Mr. Venugopala Reddy**, of **CLARUS INTERNATIONAL SCHOOL** and the building / premises is fit for occupancy up to classes 1st to 10th std with effect from 21/02/25 for a period of 5 Years in accordance with rules and subject to compliance of the specific conditions as appended.

1. Staircase width is 1.85m , height of the riser is 150mm and width of the tread is 300mm
2. Ceiling Height measured from surface of the floor is 3.00Mtrs
3. Cement concrete road is provided for the movement of fire engine in school premises.

Issued on 21-02-2025 at Bangalore.


Assistant Executive Engineer
PWD No.1, South Sub Division
Bangalore

Name: L. Gajendra
Designation: Assistant Executive Engineer
Name & Address of the Department/Office: PWD South Sub Division Bangalore